



Ref. Certif. No.

CZ-2814IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC**Product
Produit

LED industrial luminaire

Name and address of the applicant
Nom et adresse du demandeurTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the manufacturer
Nom et adresse du fabricantTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the factory
Nom et adresse de l'usineTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicRatings and principal characteristics
Valeurs nominales et caractéristiques principales230 V, 50/60 Hz, IP 66, ta=50 °C,
material PC/PC, ABS/AC TL, PC/PC TLTrademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De typeINNOVA 1.4ft, INNOVA 1.5ft
variants: 1.4ft 2600, 1.4ft 3200, 1.5 ft 3250, 1.5ft 4000Additional information (if necessary)
Information complémentaire (si nécessaire)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1
IEC 60598-2-1
IEC 624712014
1979+A1:1987
2006 Blue hazard onlyAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

704278-01/01 of: 20.02.2018

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationElektrotechnický zkušební ústav, s.p.
Pod lisem 129/2, 171 02 Praha 8 – Troja
Czech RepublicSignature: Miroslav Sedláček
Certification and Inspection Manager

Date: 09.03.2018



IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

CZ-2814-M1-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Ceiling and wall luminaires

Name and address of the applicant

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the manufacturer

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the factory

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

230 V, 50/60 Hz, max. 27 W LED, ta 50°C, IP66/69,
protection class I.

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

INNOVA 1.4ft, INNOVA 1.5ft
variants: 1.4ft 2600, 1.4ft 3200, 1.5 ft 3250, 1.5ft 4000
materials: PC/PC, ABS/AC TL, PC/PC TL

Additional information (if necessary may also be reported on page 2)

Technical Modification No. 1: 30.07.2020
New LED modules and electronic control gears added:
Modified models contains new electronic control gears and
LED modules. Construction of the luminaire remains same
as before.Technical Modification No. 2: 28.05.2021
New connection device for luminaire equipment added.
IP test results taken from Test Report Ref. No.
704279-01/01-M2 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014
IEC 60598-2-1:1979+A1:1987

As shown in the Test Report Ref. No. which forms part of this Certificate

704278-01/01 of: 20.02.2018,
704278-01/01-M1 of: 30.07.2020,
704278-01/01-M2 of: 28.06.2021

This CB Test Certificate is issued by the National Technical Body

Elektrotechnický zkušební ústav, s.p.
Pod lisem 129/2, 171 02 Praha 8 – Trojská
Czech Republic

Date: 05.08.2020



Signature:

Miroslav Sedláček
Certification and Inspection Manager

704278-01



Ref. Certif. No.

CZ-2815IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC**Product
Produit

LED industrial luminaire

Name and address of the applicant
Nom et adresse du demandeurTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the manufacturer
Nom et adresse du fabricantTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the factory
Nom et adresse de l'usineTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicRatings and principal characteristics
Valeurs nominales et caractéristiques principales230 V, 50/60 Hz, IP 66, ta=45 °C,
material PC/PC, ABS/AC TL, PC/PC TLTrademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De typeINNOVA 1.4ft, INNOVA 1.5ft
variants: 1.4ft 4400, 1.4ft 6400, 1.5ft 5500, 1.5ft 8000Additional information (if necessary)
Information complémentaire (si nécessaire)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1
IEC 60598-2-1
IEC 624712014
1979+A1:1987
2006 Blue hazard onlyAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

704279-01/01 of: 20.02.2018

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Elektrotechnický zkušební ústav, s.p.
Pod lisem 129/2, 171 02 Praha 8 – Troja
Czech Republic

Signature Miroslav Sedláček

Certification and Inspection Manager

Date: 09.03.2018



IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CZ-2815-M1IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**
CERTIFICAT D'ESSAI OCProduct
Produit

Ceiling and wall luminaires

Name and address of the applicant
Nom et adresse du demandeurTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the manufacturer
Nom et adresse du fabricantTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicName and address of the factory
Nom et adresse de l'usineTREVOS, a.s.
Mašov 34, 511 01 Turnov - Mašov, Czech RepublicRatings and principal characteristics
Valeurs nominales et caractéristiques principales230 V, 50/60 Hz, max. 54 W LED, ta 45°C, IP66/IP69,
protection class I.Trademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De typeINNOVA 1.4ft, INNOVA 1.5ft
variants: 1.4ft 4400, 1.4ft 6400, 1.5ft 5500, 1.5ft 8000
materials PC/PC, ABC/AC TL, PC/PC TLAdditional information (if necessary)
Information complémentaire (si nécessaire)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1
IEC 60598-2-12014
1979+A1:1987As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

704279-01/01-M1 of: 30.07.2020

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationElektrotechnický zkušební ústav, s.p.
Pod lisem 129/2, 171 02 Praha 8 – Troja
Czech Republic

Miroslav Sedláček
Certification and Inspection Manager

Date: 05.08.2020



IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CZ-2815-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED industrial luminaire

Name and address of the applicant

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the manufacturer

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Name and address of the factory

TREVOS, a.s.
Nová Ves 34, 511 01 Turnov, Czech Republic

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

220-240 V, 50/60 Hz, max. 54 W LED, ta 45 °C, IP66/IP69, protection class I.

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

INNOVA 1.4ft, INNOVA 1.5ft
variants: 1.4ft 4400, 1.4ft 6400, 1.5ft 5500, 1.5ft 8000,
materials PC/PC, ABC/AC TL, PC/PC TL

Additional information (if necessary may also be reported on page 2)

Technical Modification No.1: 30.07.2020
New LED modules and electronic control gears added:
Modified models contains new electronic control gears and LED modules. Construction of the luminaire remains same as before.Technical Modification No.2: 18.05.2021
New connection device for luminaire equipment added. Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60598-1 ed.6:2014,
IEC 60598-2-1:1979+A1:1987


As shown in the Test Report Ref. No. which forms part of this Certificate

704279-01/01 of: 20.02.2018,
704279-01/01-M1 of: 30.07.2020,
704279-01/01-M2 of: 18.05.2021

This CB Test Certificate is issued by the National Certification Body

Elektrotechnický zkušební ústav, s.p.
Pod lisem 129/2, 171 02 Praha 8 – Troja
Czech Republic

Date: 09.03.2018 corr. 20.05.2021


Miroslav Sedláček
Certification and Inspection Manager


704279-01